

FFT Spectrum

F(Hz)	A (m/s^2)	V (mm/s)	S(um)	Phase
-------	-----------	----------	-------	-------

Route: **SII Group/Process Area/Reactor_R3/R2-11_1DEV (2009/07/21 11:41:52 - FFT Lin (800))**

23.7975	0.3636	2.4316	16.262
25.0500	0.5656	3.5936	22.8319
26.3025	0.2047	1.2388	7.496

Root-mean-square values

1.2615	5.0413	30.6152
--------	--------	---------

General root-mean-square values

1.2615	5.0493	30.6152
--------	--------	---------

Threshold 10 dB

Route: **SII Group/Process Area/Reactor_R3/R2-11_1DEV (0917_115240 - FFT Lin (800))**

23.7975	0.5717	3.8234	25.5702
25.0500	0.9144	5.8097	36.912
26.3025	0.3502	2.1191	12.8226

Root-mean-square values

2.1539	8.3374	48.0244
--------	--------	---------

General root-mean-square values

1.8379	8.0324	47.7046
--------	--------	---------

Threshold 10 dB

Route: **SII Group/Process Area/Reactor_R3/R2-11_1DEV (1117_112030 - FFT Lin (800))**

23.7975	0.569	3.8051	25.4482
25.0500	0.8452	5.37	34.1181
48.8475	0.7456	2.4294	7.9156
50.1000	0.7527	2.3913	7.5964

Root-mean-square values

2.4182	8.5044	46.2767
--------	--------	---------

General root-mean-square values

1.9219	8.005	45.7549
--------	-------	---------

Threshold 10 dB

Route: **SII Group/Process Area/Reactor_R3/R2-10_1DEV (0125_131752 - FFT Lin (800))**

23.7975	0.5613	3.7539	25.1059
25.0500	0.885	5.6228	35.7241
26.3025	0.3396	2.0547	12.433
48.8475	0.5791	1.8868	6.1474
50.1000	0.6781	2.1542	6.8433

Root-mean-square values

2.4709	8.5485	47.2543
--------	--------	---------

General root-mean-square values

1.9202	8.0387	46.7621
--------	--------	---------

Threshold 10 dB